



1488-CPR-0114/W



Declaration of Performance DOP-03/KPS/2021/EN

1. Unique identification code of the product type:
One-wing fire vent AWAK's type in a barrel vault
2. Intended use/es:
 - **smoke, heat and toxic combustion products removal by natural air circulation**
 - **daily light transmission**
3. Manufacturer:
KERA AWAK Sp. z o.o.
64-320 Buk, ul. Dobieżyńska 56
4. AVCP - System or systems of assessment and verification of constancy of performance of the construction product:
System 1
5. Harmonised European norm:
PN-EN 12101-2:2005 / EN 12101-2:2003

Notified body:

Instytut Techniki Budowlanej Zakład Certyfikacji (NB 1488)
00-611 Warszawa, ul. Filtrowa 1
Number of the certificate: 1488-CPR-0114/W

6. Declared performance properties:

Main characteristics	Performance properties	Harmonised technical specification
Smoke effective area	In accordance with FV's label	EN 12101-2:2003
Reliability	Re 1000	EN 12101-2:2003
Snow load	SL 250	EN 12101-2:2003
Operation in low temperature	T (00)	EN 12101-2:2003
Wind load	WL 1500	EN 12101-2:2003
High temperature resistance	B 300	EN 12101-2:2003

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Buk, 08.01.2021

(place and date of issue)


Krzysztof Nosaj
Country Manager Poland

signature
KERA AWAK Sp. z o.o. ②
64-320 Buk, ul. Dobieżyńska 56
tel. +48 61 810 88 39, awak@keragroup.com
NIP 8942002405 REGON 930311125